

Nutzungsinformationen

e.Guard-Gateway



Diese Nutzungsinformationen beschreiben die Montage und Inbetriebnahme des e.Guard-Gateways. Sie richtet sich an die Elektrofachkraft. Aufgrund erheblicher Gefährdungspotenziale dürfen der Einbau und der Anschluss von Geräten dieser Art nicht durch den elektrotechnischen Laien erfolgen. Die Anleitung ist aufzubewahren, um ein späteres Nachschlagen zu ermöglichen.

Warnhinweise

Geräte mit sichtbaren Beschädigungen dürfen weder montiert noch verwendet werden.


Bestimmungsgemäßer Gebrauch und Montage

Die Geräte sind für den Einbau in Energieverteilern oder Anlagen im trockenen Innenbereich vorgesehen. Das e.Guard-Gateway ist ein Industrial IoT-Gateway zur Hutschienenmontage. Die Montage sollte mit einem seitlichen Abstand von 2 cm zu anderen Geräten erfolgen. Nur bei senkrechter Montage ist sichergestellt, dass Luft von unten nach oben durch das e.Guard-Gateway strömen kann, um das Gerät ausreichend zu kühlen. Der Einbau sollte nur in ausreichend belüftete Schaltschränke erfolgen.

Die folgenden Informationen sind für den korrekten Betrieb unbedingt zu beachten.

Technische Eigenschaften

Für die korrekte Funktion benötigt das e.Guard-Gateway eine Versorgungsspannung von 24 V DC an Klemme 1 und 2.




- 1: Spannungsversorgung 24 V DC
- 2: Masse
- 3: Nicht beschaltet
- 4: Funktionserde

Auf dem Gateway ist im Auslieferungszustand das e.Guard interface installiert. Das e.Guard interface dient zur Parametrierung der Differenzstrommonitore, zur Visualisierung und Erfassung/Übertragung von Differenzströmen. Die Registrierung für Level 2–5 erfolgt unter www.eguard.de.

Status	
PWR rot:	Hochfahren/interner Fehler
PWR grün:	Gerät ist hochgefahren und läuft
A1 blinkt grün	Gateway ist bereit, Konfiguration über USB-Stick anzunehmen
A1 gelb:	Konfiguration wird von USB gelesen
A1 rot:	Fehler beim Übernehmen der Konfiguration per USB
A1 grün:	Konfiguration wurde über USB erfolgreich übernommen (bleibt so lange grün, bis der USB-Stick abgezogen wird)
A2 blinkt orange:	Gateway sucht DHCP-Server
A2 orange nach drei Minuten:	Gateway hat auf die default IP 192.168.100.99 umgeschaltet
A2 grün:	Gateway verwendet DHCP oder die eingestellte statische IP
Ethernet grün:	Datenverkehr
Ethernet gelb an:	100 Mbps
Ethernet gelb aus:	10 Mbps


Zugangsdaten

- Benutzername: Administrator
- Passwort: admin
- Standard IP-Adresse: 192.168.100.99
- DHCP: aktiviert (Werkseinstellung)




▲ Anschlussschema e.Guard RCM, PoE-Switch und e.Guard-Gateway in Level 2.

Frontansicht e.Guard-Gateway



Ansicht von oben e.Guard-Gateway



Hinweis: Die Service-Schnittstellen (Micro-USB-Anschluss, PiBridge-Anschlüsse, Micro-HDMI-Anschluss) dienen ausschließlich zu Servicezwecken und können vom Anwender nicht genutzt werden. Durch unsachgemäßen Gebrauch kann das e.Guard-Gateway als auch die daran angeschlossene Peripherie beschädigt werden.

Gewährleistung

Für fachgerecht montierte, unveränderte Geräte gilt ab Kauf durch den Endverbraucher die gesetzliche Gewährleistungsfrist. Die Gewährleistung bezieht sich nicht auf Transportschäden sowie Schäden, die durch Kurzschluss, Überlastung oder bestimmungswidrigen Gebrauch entstanden sind. Bei Fertigungs- und Materialfehlern, die innerhalb der Gewährleistungsfrist erkannt werden, leistet unser Werk kostenlos Reparatur oder Ersatz.

e.Guard interface

Mit e.Guard interface werden die Differenzstrommonitore zentral im System verwaltet. Die erfassten Differenzströme werden visualisiert und dokumentiert. Der Zugriff mit einem Browser ist unter folgenden Adressen möglich:
[http://\[IP-Adresse\]](http://[IP-Adresse])
[http://eguardgateway\[Seriennummer\]](http://eguardgateway[Seriennummer])

www.eguard.de



Usage information

e.Guard-Gateway



This usage information describes the installation and commissioning of the e.Guard-Gateway. It is intended for use by electrically skilled personnel. Electrical laypersons must not install and connect devices of this type due to the considerable potential dangers. The instructions must be kept so that they can be referred to at a later stage.

Warning notes

Devices with visible damage must not be installed or used.


Intended use and installation

The devices are intended for installation in power distributors in dry indoor conditions. The e.Guard-Gateway is an industrial IOT gateway for DIN rail mounting. The device should be installed with a distance of 2 cm from other devices at the sides. The installation must be level in order to ensure that air can flow upwards from below through the e.Guard-Gateway and that the device is sufficiently cooled. The device should only be installed in adequately ventilated switch cabinets.

The following information must be observed to ensure correct operation.

Technical properties

In order to function correctly, the e.Guard-Gateway requires a voltage supply of 24 V DC at terminal 1 and 2.



- 1: Voltage supply 24 V DC
- 2: Mass
- 3: Not wired
- 4: Functional earth


The e.Guard interface is installed on the gateway in as-delivered condition. The e.Guard interface is used to parametrise the residual current sensors and to visualise and record/transfer residual currents. Registration for level 2-5 can be done at www.eguard.de.

Status

PWR red:	Start-up/internal error
PWR green:	Device has started up and is running
A1 flashing green:	Gateway is ready to adopt configuration via USB stick
A1 yellow:	Configuration being read from USB
A1 red:	Error when transferring configuration via USB
A1 green:	Configuration was successfully transferred via USB (stays green until the USB stick is removed)
A2 flashing orange:	Gateway searching for DHCP server
A2 orange after three minutes:	Gateway hat auf die default IP 192.168.100.99 umgeschaltet
A2 green:	Gateway has switched to the default IP 192.168.100.99
Ethernet green:	Data traffic
Ethernet yellow on:	100 Mbps
Ethernet yellow off:	10 Mbps


Login details

User name:	Administrator
Password:	admin
Standard IP address:	192.168.100.99
DHCP:	activated (factory setting)




▲ Connection diagram e.Guard RCM, PoE switch, e.Guard-Gateway in Level 2

Front view e.Guard-Gateway



Top view of e.Guard-Gateway



Note:

The service interfaces (Micro USB port, PiBridge ports, Micro HDMI port) are for service purposes only and cannot be used by the user. The e.Guard-Gateway and any peripheral equipment connected to it can be damaged by incorrect use.

Warranty

All professionally installed, unaltered devices are covered by warranty for the duration of the statutory warranty period from the day of purchase by the end user. The warranty does not apply to damage incurred during transport or caused by short-circuit, overloading or improper use. For defects in workmanship or material that are discovered within the warranty period, the company will provide repair or replacement free of charge.

e.Guard interface

e.Guard interface allows you to manage up to e.Guard RCM easily and centrally.



The detected residual currents are visualised and documented. Browser access is possible via the following addresses:

[http://\[IP-address\]](http://[IP-address])
[http://eguardgateway\[Serial number\]](http://eguardgateway[Serial number])

www.eguard.de