

Certificate of Compliance

Certificate Number:

UL-US-L254144-11-03400102-4

Report Reference:

E254144-20100430

Issue Date:

2024-10-30

Issued to:

**Guenther Spelsberg GmbH + Co. KG
Im Gewerbepark 1 Schalksmuehle 58579
Germany**

This certificate confirms that representative samples of:

BGUZ - Boxes, Junction and Pull

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 50, 13th Ed., Issue Date: 2015-10-16, Revision Date: 2020-10-15, UL 50E, 3rd Ed., Issue Date: 2020-10-15

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-L254144-11-03400102-4
Report reference E254144-20100430
Date 2024-10-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

| Model | Product Description |
|---|---|
| Enclosure series , TG PC, followed by 1612, 2012, 2015, 2516 or 3023, followed by 8, 9, 11 or 12, followed by t or 'blank', followed by -o, may be followed by /S or -SV. | Boxes, junction and pull |
| Enclosure series , Alternate Designation for bottom part, TG PC, followed by 1612, 2012, 2015, 2516 or 3023 | Boxes, junction and pull, bottom parts |
| Enclosure series , Alternate designation for transparent cover, tc or -t-o/S or -t-o-SV. | Boxes, junction and pull, transparent covers |
| Enclosure series , Alternate designation for Intransparent cover, c or -o/S or -o-SV. | Boxes, junction and pull, intransparent covers |
| Enclosure series , Accessories for use with TG PC enclosure series, for Type 12 (indoor) applications, only: Mounting means accessory/kit, model TG ABL (Cat. no. 18200201). | Boxes, junction and pull, (Accessories for use with TG PC enclosure series) |

RATINGS:

Environmental Rating:

Enclosures without quick-release fastener (/S): Type 4X, Type 12

Enclosures with quick-release fastener (-SV): Type 12

Mounting means accessory/kit, TG ABL: Suitable for Type 12 (indoor) applications only.



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

UL-CA-L254144-21-03400102-4

Report Reference:

E254144-20100430

Issue Date:

2024-10-30

Issued to:

**Guenther Spelsberg GmbH + Co. KG
Im Gewerbepark 1 Schalksmuehle 58579
Germany**

This certificate confirms that representative samples of:
BGUZ7 - Boxes, Junction and Pull Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 94.1:15, 2nd Ed., Issue Date: 2015-10-16, Revision Date: 2020-10-15, CSA C22.2 No. 94.2:20, 3rd Ed., Issue Date: 2020-10-15

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-L254144-21-03400102-4
Report reference E254144-20100430
Date 2024-10-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

| Model | Product Description |
|---|---|
| Enclosure series , TG PC, followed by 1612, 2012, 2015, 2516 or 3023, followed by 8, 9, 11 or 12, followed by t or `blank`, followed by -o, may be followed by /S or -SV. | Boxes, junction and pull |
| Enclosure series , Alternate Designation for bottom part, TG PC, followed by 1612, 2012, 2015, 2516 or 3023 | Boxes, junction and pull, bottom parts |
| Enclosure series , Alternate designation for transparent cover, tc or -t-o/S or -t-o-SV. | Boxes, junction and pull, transparent covers |
| Enclosure series , Alternate designation for Intransparent cover, c or -o/S or -o-SV. | Boxes, junction and pull, intransparent covers |
| Enclosure series , Accessories for use with TG PC enclosure series, for Type 12 (indoor) applications, only: Mounting means accessory/kit, model TG ABL (Cat. no. 18200201). | Boxes, junction and pull, (Accessories for use with TG PC enclosure series) |

RATINGS:

Environmental Rating:

Enclosures without quick-release fastener (/S): Type 4X, Type 12

Enclosures with quick-release fastener (-SV): Type 12

Mounting means accessory/kit, TG ABL: Suitable for Type 12 (indoor) applications only.



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

