



Certificate of Constancy of Performance

2652-CPR-1240484

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**Communication Cable
YELLONET 1000 S/FTP 4P C7 Cca
Cca-s1a,d1,a1**

Product detail and use see Annex 1

Placed on the market under the name:

**DEHA Elektrohandelsgesellschaft mbH
& Co. KG.
Weilimdorfer Strasse 74/2
70839 Gerlingen
Germany**

Produced in the manufacturing plant:

Záborské, Slovak Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZZ of the standard(s)

EN 50575:2014+A1:2016

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was issued on 2025.01.13 and will remain valid until 2026.01.13 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

**3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark**

www.3Ptest.dk

Hørsholm, 13th January 2025

A handwritten signature in blue ink, appearing to read 'Jens Rytter Petersen', written over a horizontal line.

**Jens Rytter Petersen
General Manager**





Annex 1 Certificate of Constancy of Performance

2652-CPR-1240484

Common use of the product
Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.

Product family:		
Cable Identification		Product parameter variations
Product Code	Description	OD/mm
7141114	YELLONET 1000 S/FTP 4P C7 Cca	7,3
7141115	YELLONET 1000 S/FTP 4P C7 Cca	7,3
7141116	YELLONET 1000 S/FTP 4P C7 Cca	7,3
7141117	YELLONET 1000 S/FTP 4P C7 Cca	7,3
7141118	YELLONET 1000 S/FTP 4P C7 Cca	7,3

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark
www.3Ptest.dk

Hørsholm, 13th January 2025


Jens Rytter Petersen
General Manager

