



Compliance Statement

Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

**DEHA Group Identification:
YELLONET 1000 KAT.7 S/FTP 2x4P AWG23**


**Cat. 7, Overall Braid Screened Cable with Foil Screened Twisted Pairs
100 Ω , 2x4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable**

**DEHA Elektrohandelsgesellschaft mbH & Co. KG.
Weilimdorfer Strasse 74/2,
70839 Gerlingen, Germany**

Compliance Statement No. 0473-3P-1250815

This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-E:2024, the requirements of CENELEC EN 50288-4-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to EN 60332-1-2 / IEC 60332-1-2, EN 61034-2 / IEC 61034-2 and EN 60754-2 / IEC 60754-2. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 23 May 2026.


Hoersholm, 23 May 2025


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 23 May 2025


Jens Rytter Petersen
General Manager