

UL-EU Certificate

Certificate
UL-EU-02655-A1

Issue date
2025-09-23

Expiration date
2026-09-06



This is to acknowledge that

Guenther Spelsberg GmbH + Co. KG

Im Gewerbepark 1 Schalksmuehle 58579
Germany

has had

Distribution Board Enclosure

AK Enclosure Types:

AK 14; AK 14 Plus; AK-F 14; AK-F 14 Plus

AK 28; AK 28 Plus; AK-F 28; AK-F 28 Plus

See page 2 for additional Information

evaluated and meets the requirements of the standard
EN 62208:2011

Test Report Nos.

4791094444.1 issued on 2025-03-10

Certification Manager
Thomas Wilson

**UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark,
Tel. +45 44 85 65 65**

This is to certify that representative sample(s) of the Product described herein ("Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL-EU Requirements. As specified in the respective sections below the designated Certificate holder is entitled to use the UL-EU Mark, or its alternative for cables, for the Certified Product manufactured at the production site(s) identified above, in accordance with the UL-EU Mark Service Agreement, including without limitation the UL-EU Mark Testing and Certification Services Service Terms. Only those Products bearing the UL-EU Mark for Europe should be considered as being covered by UL Solutions' UL-EU Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard(s) identified on this Certificate is amended or withdrawn prior the expiration date.

UL-EU CERTIFICATE

TECHNICAL DETAILS

Production site(s)

Guenther Spelsberg GmbH + Co. KG
Im Gewerbepark 1 Schalksmuehle 58579
Germany

GUENTHER SPELSBERG GMBH + CO KG
VOR DEM LOHE 3 BUTTSTAEDT 99628
Germany

Trademark



Ratings

U_i: 1000VAC / 1500VDC
U_n: 400VAC
I_n: 125A
IP65 IK08 (IK07 backside)

Additional Information

The certificate was revised to include correction due to internal system error.
This certificate replaces certificate UL-EU-02655 issued on 2025-05-29.

Models (continued from page 1)

Additional Model(s):

AK Enclosure Types:

AK 14; AK 14 Plus; AK-F 14; AK-F 14 Plus

AK 28; AK 28 Plus; AK-F 28; AK-F 28 Plus

AK 42; AK 42 Plus; AK-F 42; AK-F 42 Plus

AK 56; AK-F 56

AK 14 L-g; AK 14 L-t; AK-F 14 L-g; AK-F 14 L-t

Accessories:

- Flange plates: AK3 FL00; AK3 FL01; AK3 FL02; AK3 FL13

- Adapter plate: AK3 KFL

- Combination Screw: AK3 KS M50

- Partition Wall: AK3 TW

- DIN Rail: AK3 NS35-14 and AK3 NS35-275

Certification Mark UL-EU Mark

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Certificate Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL Solutions authorized suppliers can be found on UL Solutions online directory at www.ul.com

Alternate certification Mark for cables

As an alternative to the UL-EU Mark specified above, the alternate UL-EU Mark, displayed below, can appear on certified cables only. Minimum size is not specified, as long as the mark is legible. The following is suggested:

(UL)-EU

The alternate UL-EU Mark may be cast, stamped or molded into the cable and continue throughout the length of the cable as specified in the applicable cable standard. In the absence of such requirements in the applicable cable standard, the UL-EU mark shall appear at intervals not exceeding 550 mm.

All content shall be in accordance with the details provided on this UL-EU Certificate.