

Certificate of Compliance

Certificate Number:

20251031-S7256

Report Reference:

S7256-20251031

Issue Date:

2025-11-05

Issued to:

**Pfannenberg GmbH
Werner-Witt-Strasse 1
Hamburg 21007 Germany**

This certificate confirms that representative samples of:

AUDIBLE-SIGNAL APPLIANCES, GENERAL SIGNAL

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 464, Audible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories, Edition 11, Issue Date 04/28/2023.

CAN/ULC 525:2023, Audible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories, Edition 5, Issue Date 04/28/2023.

UL 464A, Audible Signal Appliances for General Signaling Use, Edition 1, Revision Date 03/24/2021.

UL 1638A, Visual Signal Appliances for General Signaling Use, Edition 1, Revision Date 09/21/2021.

CSA C22.2 No. 205, Signal Equipment, Edition 3, Revision Date 05/2020.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Owner



CERTIFICATE OF COMPLIANCE

Certificate number S7256
Report reference S7256-20251031
Date 2025-11-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire Alarm Equipment:

Multi Tone Alarm Sounders: Models PRO 10, PRO 10-3G/3D
Models can be rated: 12-48VDC, 115-230VAC. May be followed by -3G/3D.

General Signaling Equipment:

Multi Tone Alarm Sounder/Strobes: Models PRO L 10, PRO X 10

Model PRO L 10 can be rated: 24VAC, 12-48VDC, 115-230VAC

Model PRO X 10 can be rated: 24VAC, 115VAC, 230VAC, 24-48VDC, 24VDC

Multi Tone Alarm Sounder: PRO 10

Model PRO 10 can be rated: 12-48Vdc, 115-230Vac, 24-48VAC, 24VDC

General signaling models may be followed by –SSM (24Vdc only), -SIL (except for 24-48VAC, 24VAC), -3G/3D, -DNV (24Vdc only), -CL/WH/AM/RD/YE/BU/GR/RGB (PRO L 10 only), or -CL/WH/AM/RD/YE/BU/GR (PRO X 10 only).



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.