## Rittal – The System.

Faster - better - everywhere.



Assembly and operating instructions



ENCLOSURES

POWER DISTRIBUTION CLIMATE CONTROL

IT INFRASTRUCTURE > SOFTWARE & SERVICES

## Foreword

## EN

**Foreword** Dear Customer,

Thank you for choosing our CMC III CAN bus sensor (referred to hereafter as "CAN bus sensor")!

We wish you every success.

Yours Rittal GmbH & Co. KG

Rittal GmbH & Co. KG Auf dem Stützelberg

35745 Herborn Germany

Tel.: +49(0)2772 505-0 Fax: +49(0)2772 505-2319

E-mail: info@rittal.com www.rittal.com www.rittal.de

We are always happy to answer any technical questions regarding our entire range of products.

### Contents

| 1<br>1.1<br>1.2<br>1.3<br>1.4                                     | Notes on documentation<br>CE labelling<br>Storing the documents<br>Symbols used in these operating instructions<br>Associated documents  | 4<br>4<br>s 4                        |
|---|--|--------------------------------------|
| 2<br>2.1<br>2.2   | Safety instructions<br>General safety instructions<br>Service and technical staff  | 5                                    |
| 3<br>3.1<br>3.1.1<br>3.1.2<br>3.2<br>3.3                          | Product description<br>Function description and components<br>Function<br>Components<br>Proper use, foreseeable misuse<br>Scope of supply  | 6<br>6<br>6                          |
| 4<br>4.1<br>4.2   | Transport and handling<br>Transport<br>Unpacking   | 7                                    |
| 5<br>5.1<br>5.2<br>5.3<br>5.3.1<br>5.3.2<br>5.3.3<br>5.4          | Installation   | 8<br>8<br>8<br>8<br>8                |
| 6<br>6.1<br>6.2<br>6.3<br>6.3.1<br>6.3.2<br>6.4<br>6.4.1<br>6.4.2 | Operation<br>Activating the CAN bus sensor<br>Operating and display elements<br>LED displays<br>Multi-LED displays<br>LED displays on the CAN bus connection<br>Operating the CMC III Processing Unit from<br>the website<br>Device<br>Input | . 11<br>. 11<br>. 11<br>. 11<br>. 11 |
| 7<br>7.1<br>7.2   | Storage and disposal<br>Storage<br>Disposal  |                                      |
| 8   | Technical specifications   | 15                                   |
| 9   | Customer service addresses   | 16                                   |

## EN

1

### Notes on documentation

#### 1.1 CE labelling

Rittal GmbH & Co. KG hereby confirms that the CMC III CAN bus sensor is compliant with the EU EMC Directive 2014/30/EU. An appropriate declaration of conformity has been prepared. It can be provided on request.

# CE

#### **1.2 Storing the documents**

The operating, installation and maintenance instructions as well as all applicable documents are an integral part of the product. They must be passed to those persons who are engaged with the unit and must always be available and on hand for the operating and maintenance personnel.

#### 1.3 Symbols used in these operating instructions

The following symbols are used in this documentation:



Danger!

A dangerous situation in which failure to comply with the instructions causes death or severe injury.



#### Warning!

A hazardous situation which may lead to death or serious injury if the instructions are not followed.



#### Caution!

A hazardous situation which may lead to (minor) injuries if the instructions are not followed.



#### Note:

Identification of situations that can lead to material damage.

This symbol indicates an "action point" and shows that you should perform an operation or procedure.

#### 1.4 Associated documents

- Installation instructions and Short User's Guide
- CMC III Processing Unit/CMC III Processing Unit Compact assembly, installation and operating instructions
- Installation instructions and Short User's Guide for the connected accessories (e.g. motion detector DK 7320.570).

EN

### 2 Safety instructions

#### 2.1 General safety instructions

Please observe the subsequent general safety instructions for the installation and operation of the system:

- Use only original Rittal products or products recommended by Rittal in conjunction with the CAN bus sensor.
- Please do not make any changes to the CAN bus sensor that are not described in this manual or in the associated manuals.
- The operating reliability of the CAN bus sensor is only warranted in case of use as intended and according to the rules. The technical specifications and limit values stated must not be exceeded under any circumstances. In particular, this applies to the specified ambient temperature range and IP degree of protection.
- The CAN bus sensor may not be opened. The unit does not contain any parts that need servicing.
- The operation of the system in direct contact with water, aggressive materials or inflammable gases and vapours is prohibited.
- Other than these general safety instructions, ensure you also observe the specific safety instructions when the tasks described in the following chapters are performed.

#### 2.2 Service and technical staff

- The mounting, installation, commissioning, maintenance and repair of this unit may only be performed by qualified mechanical and electro-technical trained personnel.
- Only properly instructed personnel may work on a unit while in operation.

### EN

3

### Product description

#### 3.1 Function description and components

#### 3.1.1 Function

The CAN bus sensor provides the capability to integrate a previous-generation CMC-TC sensor into the CMC III system. It provides the values measured by this sensor to the connected CMC III Processing Unit. The CAN bus sensor has an identification that allows it to be detected automatically by the CMC III Processing Unit.

## Note:

In the following text the designation "CMC III Processing Unit" refers to both the "CMC III Processing Unit" and also the "CMC III Processing Unit Compact". All of the text passages which only apply for one of the two variants are labelled accordingly.

#### 3.1.2 Components

The device consists of a compact plastic housing in RAL 7035 with a ventilated front in RAL 9005.

#### 3.2 Proper use, foreseeable misuse

The CAN bus sensor is used only for the connection of a CMC-TC sensor and the integration of this sensor in the CMC III system. It may only be used together with the CMC III Processing Unit. Any other use is not permitted.

The unit is state of the art and built according to recognised safety regulations. Nevertheless, incorrect use may result in damage to or faults with the system and other material assets.

Consequently, the unit must only be used properly and in a technically sound condition! Any malfunctions which impair safety should be rectified immediately. Follow the operating instructions!

The intended use also includes the observance of the documentation provided and fulfilling the inspection and maintenance conditions.

Rittal GmbH & Co. KG is not liable for any damage which may result from failure to comply with the documentation provided. The same applies to failure to comply with the valid documentation for the accessories used.

Inappropriate use may result in danger. Inappropriate use includes:

- Use of impermissible tools.
- Improper operation.
- Improper rectification of malfunctions
- Use of accessories not approved by Rittal GmbH & Co. KG.

#### 3.3 Scope of supply

- CAN bus sensor
- Accessories provided (fig. 1)
- Installation and Short User's Guide

| 2x (       | → M5x14  | 2x (  | M4x10 |
|------------|----------|-------|-------|
| 2x 💮       | 5,3      | 2x () | A 5,3 |
| 2x 🔘       | M5       | 2x 🔘  | A 4,3 |
| 2x (100000 | ₪ 5,5x13 | 2x 🔘  | 4,3   |
| 5x 🖘       |          |       |       |
| 1x         | þ        | 1x    |       |

Fig. 1: Accessories provided

### 4 Transport and handling

#### 4.1 Transport

The unit is delivered in a carton.

#### 4.2 Unpacking

■ Remove the unit's packaging materials.



After unpacking, the packaging materials must be disposed of in an environmentally friendly way. It consists of the following materials:

Polyethylene film (PE film), cardboard.

Check the unit for any damage that occurred during transport.



Note:

Damage and other faults, e.g. incomplete delivery, should immediately be reported to the shipping company and to Rittal GmbH & Co. KG in writing.

- Remove the unit from the PE film.
- Remove the protective film from the front cover of the device.

## 5 Installation

EN

#### 5.1 Safety instructions

- Please observe the valid regulations for installation in the country in which the CAN bus sensor is installed and operated, and the national regulations for accident prevention. Please also observe any company-internal regulations, such as work, operating and safety regulations.
- The technical specifications and limit values stated may not be exceeded under any circumstances. In particular, this applies to the specified ambient temperature range and IP degree of protection.
- If a higher IP protection class is required for a special application, the CAN bus sensor must be installed in an appropriate housing or in an appropriate enclosure with the required IP degree of protection.

#### 5.2 Siting location requirements

To ensure the correct function of the unit, the conditions for the installation site of the unit specified in section 8 "Technical specifications" must be observed.

#### **Electromagnetic interference**

- Interfering electrical installations (high frequency) should be avoided.

#### 5.3 Installation procedure

There are two general options for installing the CAN bus sensor:

- 1. Installation on the frame of the enclosure or IT enclosure using the bracket included.
- 2. Installation on a top-hat rail using the bracket included along with a spring clip.

#### 5.3.1 Installation notes

The CAN bus sensor must be positioned so that it is ventilated with an adequate amount of air and the ventilation slots are not covered.

#### 5.3.2 Installation with the mounting bracket provided

It can be mounted on the frame of the IT enclosure using the bracket included in the scope of delivery.

■ Place the CAN bus sensor on the bracket from above.



Fig. 2: Attaching the sensor to the bracket

Move the sensor sideways slightly on the bracket, so that it latches into place.



Fig. 3: Latching the sensor into place on the bracket

Mount the bracket and the CAN bus sensor in the desired position in the enclosure or the IT enclosure using the screw included in the scope of delivery.



Fig. 4: Mounting the sensor in the enclosure or IT enclosure

#### 5.3.3 Installation on a top-hat rail

The sensor can also be mounted on a top-hat rail using the bracket along with the spring clip included in the scope of delivery.

■ First screw the bracket onto the spring clip provided for installation on a top-hat rail.

## 5 Installation



Fig. 5: Fastening the bracket to the spring clip

- Then place the CAN bus sensor on the bracket (fig. 2) and latch it in place (fig. 3).
- Latch the spring clip into place at the desired position on the top-hat rail.



Fig. 6: Fastening the spring clip to the top-hat rail

#### 5.4 Connecting the sensor

The CAN bus connection supplies the CAN bus sensor with the necessary operating voltage. A separate power supply unit does not need to be connected.



Fig. 7: Rear of the CAN bus sensor

- Key
- 2 CAN bus connection, 24 V ---
- 3 CAN bus connection, 24 V ---
- 4 Connection for CMC TC sensor RJ 12
- Connect one of the following CMC TC sensors to the appropriate connection (fig. 7, item 4).
  - Temperature sensor (DK 7320.500)
  - Analogue input 4-20 mA (DK 7320.520)
  - Access sensor, max. 5 sensors in series supported, (DK 7320.520)
  - Airflow sensor (DK 7320.550)
  - Smoke detector (DK 7320.560)
  - Motion detector (DK 7320.570)
  - Digital sensor input (DK 7320.580)

- Digital actuator output (DK 7320.590)
- Voltage monitoring (DK 7320.600)
- 48 V voltage sensor (DK 7320.620)
- Leak sensor (DK 7320.630)
- Leak sensor, 15 m sensory system (DK 7320.631)
- Door Control Unit (DK 7320.790)
- Fire alarm and extinguisher system DET-AC Plus (DK 7338.120)
- Early fire detection system EFD Plus (DK 7338.220)
- Use a CAN bus connection cable to connect the CAN bus sensor to a CAN bus interface on the CMC III Processing Unit or of the neighbouring component on the CAN bus (fig. 7, item 2).

The following CAN bus connection cables from the CMC III accessories can be used:

- DK 7030.090 (length 0.5 m)
- DK 7030.091 (length 1 m)
- DK 7030.092 (length 1.5 m)
- DK 7030.093 (length 2 m)
- DK 7030.480 (length 3 m)
- DK 7030.490 (length 4 m)
- DK 7030.094 (length 5 m)
- DK 7030.095 (length 10 m)



Fig. 8: Front of the CAN bus sensor

Key

1 Multi-LED for status display

The sensor software is updated, if necessary, after being connected. The status LED of the CAN bus sensor glows blue throughout the entire update process and also flashes purple while the sensor itself is being updated. In addition, the status LED of the CMC III Processing Unit flashes white and a corresponding message appears on the website.

Note:

No settings can be modified as long as the update process is running.

The update of the sensor is complete when the following conditions have been fulfilled:

- 1. The LEDs on the CAN bus connection of the sensors light green.
- 2. The multi-LED of the sensor behind the front panel flashes blue and green, yellow or red, depending on the condition of the sensor.

Further components are connected as a daisy chain.

9

## 5 Installation

■ If necessary, connect another component (e.g. another sensor type) to the second, free CAN bus interface of the CAN bus sensor (fig. 7, item 3).

#### Status change display:

- The two green and the two red CAN bus LEDs on the CAN bus connection flash.
- The multi-LED of the Processing Unit flashes continually in the sequence green - yellow - red.
- The multi-LED of the CAN bus sensor flashes blue continuously.
- Press the "C" key on the CMC III Processing Unit (an initial audio signal will sound) and keep it pressed for approx. 3 seconds until a second audio signal is heard.



See section 6.3.1 "Multi-LED displays" for a list of all of the multi-LED displays.

#### Replacing the CMC TC sensor attached to the **CAN** bus sensor

- If the connected sensor is replaced with the same sensor type then the sensor is automatically identified. No confirmation is necessary.
- If the connected sensor is replaced by a different type of sensor, the CAN bus sensor is de-registered and reidentified. This status change must be confirmed on the CMC III Processing Unit.
- To confirm, press the "C" key on the CMC III Processing Unit (an initial audio signal will sound) and keep it pressed for approx. 3 seconds until a second audio signal is heard.

### 6 Operation

#### 6.1 Activating the CAN bus sensor

After connecting the CAN bus sensor to a neighbouring component using a CAN bus connecting cable, the CAN bus sensor starts automatically (see section 5.4 "Connecting the sensor"). Separate activation is not required.

#### 6.2 Operating and display elements



Fig. 9: Front of the CAN bus sensor

#### Key

1 Multi-LED for status display



Fig. 10: Rear of the CAN bus sensor

#### Key

- 2 CAN bus connection, 24 V ---
- 3 CAN bus connection, 24 V ---
- 4 Connection for CMC TC sensor RJ 12

#### 6.3 LED displays

A multi-LED for the status display is integrated into the front of the CAN bus sensor (fig. 9, item 1). Additional LEDs are located at the rear on the CAN bus connection (fig. 10, item 2 and item 3).

#### 6.3.1 Multi-LED displays

The status of the CAN bus sensor can be read on the multi-LED.

#### **Continuously lit**

| Colour | Status                 |
|--------|------------------------|
| Red    | Invalid measured value |

Tab. 1: Multi-LED continuously lit

#### **Flashing codes**

| Colour | Status  |
|--------|---|
| Green  | When the measured value changes or, at the latest, every 5 seconds. |
| Purple | A CAN bus sensor software update is be-<br>ing carried out.         |
| Blue   | Communication via the CAN bus.                                      |

Tab. 2: Multi-LED flashing codes

#### 6.3.2 LED displays on the CAN bus connection

A red and a green LED are located on the CAN bus connection. They display the status of the CAN bus.

| Colour                        | Status                                  |
|-------------------------------|---|
| Green (con-<br>tinuously lit) | Communication via the CAN bus possible. |
| Red (flash-<br>ing)           | Transmission fault.                     |

Tab. 3: LEDs for the CAN bus connection

## 6.4 Operating the CMC III Processing Unit from the website

After logging on to the CMC III Processing Unit, the web interface for operating the device is displayed.

■ First select the "CMCIII-SEN" entry in the navigation area.

Similar to the CMC III Processing Unit, the **Configura**tion tab can be used to individually configure the access rights for the CAN bus sensor (**Access Rights** button) and the alarm messages (**Alarm Configuration** button).

The **Observation** tab is used to configure all of the settings for the CAN bus sensor and the connected accessories. The "Device" level enables you to configure all of the general settings which apply to the CAN bus sensor. The parallel level depends on the sensor connected.

In the following sections 6.4.1 "Device" and 6.4.2 "Input", only those parameters which you can modify are described. There are also display values that provide information.

#### 6.4.1 Device

General settings for the CAN bus sensor are configured at the "Device" level.

| Parameter   | Explanation                                  |
|-------------|--|
| Description | Specific description of the CAN bus sensor.  |
| Location    | Installation location of the CAN bus sensor. |

Tab. 4: Settings in the "Device" level

In addition, parameters that provide detailed information about the CAN bus sensor, such as the version of the deployed software and hardware, are also displayed. You should have such information available, in particular to enable rapid troubleshooting when requesting assistance from Rittal.

#### 6.4.2 Input

When a sensor is connected to the CAN bus sensor, another level is displayed in addition to the "Device" level.

## 6 Operation

EN

The settings for the sensor are configured on this level. The name of this level depends on the connected sensor type.

| Parameter | Explanation  |
|-----------|--|
| DescName  | Specific description of the connected sensor.      |
| Delay     | Time delay after which the status message changes. |

Tab. 5: Settings in the "Input" level

The following parameters are also displayed for the connected sensor:

| Parameter | Explanation   |
|-----------|---|
| Value     | Current value of the sensor.  |
| Status    | Current status of the sensor, taking into ac-<br>count the delay value. |

Tab. 6: Displays in the "Input" level

The individual sensors can have the following states:

| Sensor \ Status             | Value 0 | Value 1 |
|-----------------------------|---------|---------|
| Access sensor (DK 7320.530) | Open    | Closed  |

Tab. 7: Sensors with the status display "Open/Closed"

| Sensor \ Status   | Value 0 | Value 1 |
|---|---------|---------|
| Airflow sensor (DK 7320.550)                                      | Alarm   | OK      |
| Smoke detector (DK 7320.560)                                      | Alarm   | OK      |
| Motion sensor (DK 7320.570)                                       | Alarm   | OK      |
| Voltage monitoring (DK 7320.600)                                  | Alarm   | OK      |
| 48 V voltage sensor<br>(DK 7320.620)                              | Alarm   | ОК      |
| Fire alarm and extinguisher sys-<br>tem DET-AC Plus (DK 7338.120) | Alarm   | OK      |
| Early fire detection system<br>EFD Plus (DK 7338.220)             | Alarm   | ОК      |

Tab. 8: Sensors with the status display "Alarm/OK"

| Sensor \ Status                                      | Value 0 | Value 1 |
|--|---------|---------|
| Leakage sensor (DK 7320.630)                         | OK      | Alarm   |
| Leakage sensor, 15 m sensory<br>system (DK 7320.631) | OK      | Alarm   |

Tab. 9: Sensors with the status display "OK/Alarm"

| Sensor \ Status                          | Value 0 | Value 1 |
|--|---------|---------|
| Digital actuator output<br>(DK 7320.590) | Off     | On      |
| Door control unit (DK 7320.790)          | Off     | On      |

Tab. 10: Sensors with the status display "Off/On"

#### Temperature sensor (DK 7320.500)

The following settings are configured on the "Input" level for the temperature sensor.

| Parameter             | Explanation   |  |
|-----------------------|---|--|
| SetPtHigh-<br>Alarm   | Upper limit temperature for which an alarm message is issued when exceeded.   |  |
| SetPtHigh-<br>Warning | Upper limit temperature for which a warn-<br>ing message is issued when exceeded.   |  |
| SetPtLow-<br>Warning  | Lower limit temperature for which a warn-<br>ing message is issued when fallen below.   |  |
| SetPtLow-<br>Alarm    | Lower limit temperature for which an alarm message is issued when fallen below.   |  |
| Hysteresis            | The necessary percentage deviation for<br>falling below or exceeding the limit temper-<br>ature to trigger a status change (see the<br>assembly, installation and operating in-<br>structions for the CMC III Processing Unit). |  |

Tab. 11: Settings in the "Input" level

The following parameters are also displayed for the temperature sensor:

| Parameter | Explanation  |  |
|-----------|--|--|
| Value     | Currently measured temperature value.                                  |  |
| Status    | Current status of the sensor, taking into ac-<br>count the hysteresis. |  |

Tab. 12: Displays in the "Input" level

Note:

If the value "0" is entered for all limit values at the "Input" level, the status of the temperature sensor is always "OK".

#### Analogue input (DK 7320.520)

The following settings are configured on the "Input" level for the analogue input.

| Parameter             | Explanation  |  |
|-----------------------|--|--|
| SetPtHigh-<br>Alarm   | Upper limit for which an alarm message is is issued when exceeded. |  |
| SetPtHigh-<br>Warning | Upper limit for which a warning message is issued when exceeded.   |  |

Tab. 13: Settings in the "Input" level

| Parameter            | Explanation   |  |
|----------------------|---|--|
| SetPtLow-<br>Warning | Lower limit for which a warning message is is issued when fallen below.   |  |
| SetPtLow-<br>Alarm   | Lower limit for which an alarm message is issued when fallen below.   |  |
| Hysteresis           | The necessary percentage deviation for<br>falling below or exceeding the limit to trig-<br>ger a status change (see the assembly, in-<br>stallation and operating instructions for the<br>CMC III Processing Unit). |  |

Tab. 13: Settings in the "Input" level

The following parameters are also displayed for the analogue input:

| Parameter | Explanation  |  |
|-----------|--|--|
| Value     | Currently measured value.  |  |
| Status    | Current status of the analogue input taking into account the hysteresis. |  |

Tab. 14: Displays in the "Input" level

#### Note:

If the value "0" is entered for all limit values at the "Input" level, the status of the analogue input is always "OK".

#### Digital sensor input (DK 7320.580)

The following settings are configured on the "Input" level for the digital sensor input.

| Parameter | Explanation  |  |
|-----------|--|--|
| Delay     | Time delay after which the status message changes. |  |

Tab. 15: Settings in the "Input" level

The following parameters are also displayed for the digital sensor input:

| Parameter | Explanation   |  |
|-----------|---|--|
| Value     | The current value of the input (0 or 1).  |  |
| Status    | The current status of the digital sensor in-<br>put taking into account the delay value (0 =<br>OK, 1 = Alarm for "Normally Open" or 0 =<br>Alarm, 1 = OK for "Normally Closed"). |  |

Tab. 16: Displays in the "Input" level

## 7 Storage and disposal

#### 7.1 Storage

EN

If the device is not used for a long period, Rittal recommends that it is disconnected from the mains power supply and protected from damp and dust.

#### 7.2 Disposal

Since the CAN bus sensor consists mainly of the "housing" and "circuit board" parts, the device must be passed on to the electronic waste recycling system for disposal.

## 8 Technical specifications

| Technical specifications    |                         | CAN bus sensor                          |
|-----------------------------|-------------------------|---|
| Model no.                   |                         | DK 7030.100                             |
| W x H x D (mm)              |                         | 110 x 30 x 40                           |
| Operating temperature range |                         | 0°C+55°C                                |
| Storage temperature         |                         | -45°C+85°C                              |
| Operating humidity range    |                         | 5%95% relative humidity, non-condensing |
| Protection category         |                         | IP 30 to IEC 60 529                     |
| Inputs and outputs          | CAN bus (RJ 45)         | 2 x                                     |
|                             | RJ 12 C (CMC TC Sensor) | 1 x                                     |
| Operation/signals           | LED display             | OK/Warning/Alarm/CAN bus status         |

Tab. 17: Technical specifications

EN

## 9 Customer service addresses

## EN

## 9 Customer service addresses

For technical queries, please contact: Tel.: +49(0)2772 505-9052 E-mail: info@rittal.com Homepage: www.rittal.com

For complaints or service requests, please contact: Tel.: +49(0)2772 505-1855 E-mail: service@rittal.de

# Rittal – The System.

## Faster – better – everywhere.

- Enclosures
- Power Distribution
- Climate Control
- IT Infrastructure
- Software & Services

You can find the contact details of all Rittal companies throughout the world here.



www.rittal.com/contact



POWER DISTRIBUTION CLIMATE CONTROL

IT INFRASTRUCTURE > SOFTWARE & SERVICES



FRIEDHELM LOH GROUP