



Manual release button HAT 02



Function

According to the DIBt guidelines each locking device must also be able to be released by hand, without impairing the functional standby of the release device. The manual release button must be coloured red. Its housing must have the inscription: „Door release“.

Mounting

The button must be in direct proximity of the connection and may not be covered by the arrested connection. It must be well visible and easily accessible. It is preferably mounted at a height of 1.40 m \pm 20 cm.

The provided surface mount socket is not required for in-wall mounting of the manual release button HAT 02 in a switchbox.

Connection

The manual release button must release the closing lock after briefly pressing once. The closing procedure may not be able to be interrupted by repeated pressing.

Technical data

Switching voltage	max. 24 V DC
Switching current	max. 1 A
Protection system HAT 02	IP 20

Specifications subject to change without notice. Delivery subject to availability.

www.hekatron.de
rs-info@hekatron.de

Hekatron Vertriebs GmbH
Brühlmatten 9
D-79295 Sulzburg
Telephone (0 76 34) 5 00-2 64
Fax (0 76 34) 5 00-3 23

HEKATRON

A member of the
Swiss Securitas Group