

DECLARATION OF PERFORMANCE (DoP) N° 1008/17

| | |
|-----------------------|---------------|
| • Product type | H05V-U |
|-----------------------|---------------|

| | |
|-----------------------|--|
| • Intended use | Cables for the distribution of electrical power, control and telecommunications, installed in residential buildings or other civil construction, subjected to the requirements for reaction to fire. |
|-----------------------|--|

| | |
|-----------------------|--|
| • Manufacturer | Baldassari Cavi Viale Europa 118/220 55013 Lammari - Capannori (Lucca) - Italy Tel. +39 0583 43521 www.baldassaricavi.it |
|-----------------------|--|

| | |
|----------------------|---|
| • AVCP System | 3 |
|----------------------|---|

| | |
|------------------------------|-------------------------|
| • Harmonized Standard | EN 50575:2014 + A1:2016 |
|------------------------------|-------------------------|

| | |
|------------------------|---------|
| • Notified Body | NB 2479 |
|------------------------|---------|

| | |
|---------------------------|-----------------|
| • Reaction to fire | E _{ca} |
|---------------------------|-----------------|

| | |
|-------------------------------|------|
| • Hazardous substances | None |
|-------------------------------|------|

The above mentioned product performance complies with the declared reaction of fire.
This declaration of performance has been drawn up under the sole responsibility of the manufacturer mentioned above.

Signed on behalf of the manufacturer: Responsible of R&D, Ing. Eduardo Redondo



Lucca, February 2nd, 2017