

ELSEWEDY CABLES

DOP Document Number : UCCE-13-17

Standard & product range.

NYCY.

Sr.	Number of Cores	Conductor Size
1	2	1.5/1.5mm ² to 6/6mm ²
2	3	1.5/1.5mm ² to 6/6mm ²
3	4	1.5/1.5mm ² to 6/6mm ²
4	5	1.5/1.5mm ² to 6/6mm ²
5	7	1.5/1.5mm ² to 6/6mm ²
6	8	4/4mm ²
7	10	1.5/2.5mm ² to 2.5/4mm ²
8	12	1.5/2.5mm ² to 4/6mm ²
9	14	1.5/2.5mm ² to 2.5/6mm ²
10	16	1.5/4mm ² to 2.5/6mm ²
11	19	1.5/4mm ² to 2.5/6mm ²
12	21	1.5/6mm ²
13	24	1.5/6mm ² to 2.5/10mm ²
14	30	1.5/6mm ² to 2.5/10mm ²
15	40	1.5/10mm ² to 2.5/10mm ²
16	52	1.5/10mm ²
17	61	1.5/10mm ²

Traceability of each cable is followed by drum numbers

Intended Use of Product Type

Supply of electricity in buildings and other civil engineering
Works with the objective of limiting the generation and spread of fire and smoke

Manufacturer Information

Manufacturer : UIC (United Industries Cables)
=EL SEWEDY CABLES=
Office: plot 27, 1st district.5th settlement, new Cairo.
Tel: 72599732-27599733-27599734 **Fax:** 27599735 P.O.Box:311-post code: 11853

Factory Address WWW.ELSEWEDY.COM
Factory: 10th of Ramadan City Zone, A 3,
Tel.: (2015) 411350 **fax:** (2015)411366 **PO.Box:** 1748 post code: 10505

System or Systems of Assessment and Verification of Constancy of Performance

System 3

Notified Body/laboratory

BASEC No. 2661

Performances Declared

Essential Characteristic	Performance	Harmonized Technical Specification
<i>Reaction to Fire</i>	Eca	EN 50575:2014+A1:2016
<i>Smoke Production</i>	-	
<i>Flaming Droplets</i>	-	
<i>Acidity</i>	-	
<i>Dangerous substance</i>	NPD	

This declaration of performance is issued under the responsibility of the identified manufacturer.

Eng. Haitham M. Aly

Quality Assurance Manager

Haitham

Declaration Of Performance (DOP)