

DOP Document Number : UCCE-14-18

Standard & product range.

YSLY.

Sr.	Number of Cores	Conductor Size
1	3	0.5 mm ² -16mm ²
2	4	0.5 mm ² -16mm ²
3	5	0.5 mm ² -16mm ²
4	6	1.5 mm ²
5	7	0.5 mm ² -16mm ²
6	8	0.5 mm ² -1.5mm ²
7	9	0.75 mm ² -1.5mm ²
8	10	0.5 mm ² -1.5mm ²
9	11	1.5 mm ²
10	12	0.5 mm ² -2.5mm ²
11	14	0.5 mm ² -2.5mm ²
12	15	0.75 mm ²
13	16	1.0 mm ² -2.5mm ²
14	18	0.5 mm ² -2.5mm ²
15	19	1.0 mm ²
16	20	1.0 mm ² -2.5mm ²
17	21	1.0 mm ² -2.5mm ²
18	25	0.5 mm ² -2.5mm ²
19	30	0.5 mm ² -0.75mm ²
20	32	1.5 mm ²
21	34	0.5 mm ² -2.5mm ²
22	40	0.5 mm ² -2.5mm ²
23	41	1.0 mm ²
24	42	0.5 mm ² -2.5mm ²
25	50	0.5 mm ² -2.5mm ²
26	61	0.5 mm ² -2.5mm ²
27	65	0.5 mm ² -1.5mm ²
28	80	1.5 mm ²
29	100	1.5 mm ²

Traceability of each cable is followed by drum numbers

Intended Use of Product Type

Supply of electricity in buildings and other civil engineering
Works with the objective of limiting the generation and spread of fire and smoke

Manufacturer Information

Manufacturer :	UIC (United Industries Cables) =EL SEWEDY CABLES=
Factory Address	Office: plot 27, 1st district, 5th settlement, new Cairo. Tel: 72599732-27599733-27599734 Fax: 27599735 P.O.Box:311-post code: 11853 WWW.ELSEWEDY.COM Factory: 10th of Ramadan City Zone, A 3, Tel.: (2015) 411350 fax: (2015)411366 PO.Box: 1748 post code: 10505

System or Systems of Assessment and Verification of Constasy of Performance

System 3

Notified Body/laboratory

BASEC No. 2661

Performances Declared

Essential Characteristic	Performance	Harmonized Technical Specification
Reaction to Fire	Eca	EN 50575:2014+A1:2016
Smoke Production	-	
Flaming Droplets	-	
Acidity	-	
Dangerous substance	NPD	

This declaration of performance is issued under the responsibility of the identified manufacturer.

Eng. Haitham M. Aly
Quality Assurance Manager

Handwritten signature

Declaration Of Performance (DOP)