



Compliance Statement

Screened Category 7_A ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable


DEHA Group Identification:
YELLONET 1500 KAT.7A S/FTP 2x4P AWG22
Category 7_A, Individual Foil and Overall Braid Screened
100 Ω, 2x4 Twisted Pairs, 22 AWG, Flame Retardant, LSHF, Copper Cable

DEHA Group Elektrohandelsgesellschaft mbH & Co. KG.
Weilimdorfer Strasse 74/2
70839 Gerlingen, Germany


Compliance Statement No. 1191116

This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7_A performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2018, edition 2.1 of IEC Cable Standard 61156-5:2012, the Category 6_A requirements of ANSI/TIA Generic Cabling Standard 568.2-D:2018 and the requirements of CENELEC Cable Standard EN 50288-9-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment.1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 20th February 2019


Ole Lambertsen
Test Responsible

Hoersholm, 20th February 2019


Jens Rytter Petersen
General Manager