



# Certificate of Compliance

**Certificate:** 70071163

**Master Contract:** 153184

**Project:** 70071163

**Date Issued:** 2016-04-10

**Issued to:** Rittal GmbH & Co. KG  
Auf dem Stuetzelberg  
Herborn, 35745  
GERMANY  
**Attention:** Thorsten Heimberg

*The products listed below are eligible to bear the CSA Mark shown*



Issued by: Sven Renke  
*Sven Renke*

## PRODUCTS

CLASS 3211 02 - INDUSTRIAL CONTROL EQUIPMENT - Kits

Filter fan kits, models SK 3139.100, 3139.110, 3140.100, 3140.110, 3140.140, 3140.500, 3140.510

Filter kits, models SK 3138.000

Filter mat, accessory, cat. No.: 3174.100

## RATINGS

Filter fan kits bear the following ratings.

Model Cat. No.	Voltage	AC/DC	Frequency	Wattage	Max. Surrounding temp.
	[V]		[Hz]	[W]	[°C]
3139.100	230	ac	50 / 60	52 / 65	55
3139.110	115	ac	50 / 60	53 / 66	55
3140.100	230	ac	50 / 60	102 / 135	55



**Certificate:** 70071163

**Master Contract:** 153184

**Project:** 70071163

**Date Issued:** 2016-04-10

3140.110	115	ac	50 / 60	105 / 140	55
3140.140	400	ac	50 / 60	98 / 130	55
3140.500	230	ac	50 / 60	168	55
3140.510	115	ac	50 / 60	170	55

Filter kit bear the following ratings.

Model Cat. No.	Voltage	AC/DC	Frequency	Wattage	Max. Surrounding temp.
	[V]		[Hz]	[W]	[°C]
3138.000	N/A	N/A	N/A	N/A	55

Notes:

1. These devices have been evaluated for environmental Type Ratings, Type 12, if mounted according to manufacturing instruction and used with manufacturer's filter mat, cat. No.: 3174.100.
2. The suitability of these fans for use with a solid state control has not been evaluated.
3. Filter mat, accessory, cat. No.: 3174.100 is intended for use with filter fan kits, cat. No.: 3139.100, 3139.110, 3140.100, 3140.110, 3140.140, 3140.500, 3140.510 and filter kits, cat. No.: 3138.000. Suitability with other than the above noted models was not evaluated and shall be considered in the end use.

**APPLICABLE REQUIREMENTS**

CSA C22.2 No.14-13 - Industrial control equipment - Twelfth Edition  
 CSA C22.2 NO.94.1-15 - Enclosures for electrical equipment, non-environmental considerations - Second Edition  
 CSA C22.2 NO.94.2-15 - Enclosures for electrical equipment, environmental considerations - Second Edition



## *Supplement to Certificate of Compliance*

**Certificate:** 70071163 (059132\_0\_000)

**Master Contract:** 153184

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70071163	2016-04-10	Original certification of Filter fan kits type SK31xx.