



Certificate of Compliance

Certificate: 1672556

Master Contract: 153184

Project: 70000067

Date Issued: February 25, 2013

Issued to: **Rittal GmbH & Co. KG**
Auf dem Stuetzelberg 18
Herborn, 35745
Germany
Attention: Rüdiger Gilardi

The products listed below are eligible to bear the CSA Mark shown



Nitin Bhople

Issued by: Nitin Bhople

PRODUCTS

CLASS 3211 02 - INDUSTRIAL CONTROL EQUIPMENT - Kits

CLASS 1211 02 - COMFORT CONDITIONING EQUIPMENT - Air Conditioning Apparatus

Air conditioning apparatus, Series SK 3303 , models SK3303.110, .114, .210, .510, .514 and SK 3303.610 rated 115 Vac – 60Hz single phase; models SK3303.100, .104, .200, .500, .504 and SK 3303.600 rated 230 V - 60Hz single phase, All with refrigerant R-134a, Design Pressure 400 psig.

Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 236-11 - Heating and Cooling Equipment