



# Certificate of Compliance

**Certificate:** 1672838

**Master Contract:** 153184

**Project:** 70000069

**Date Issued:** August 13, 2013

**Issued to:** **Rittal GmbH & Co. KG**  
**Auf dem Stuetzelberg 18**  
**Herborn, 35745**  
**Germany**  
**Attention: Rüdiger Gilardi**

*The products listed below are eligible to bear the CSA Mark shown*



*Nitin Bhople*

**Issued by:** Nitin Bhople

## **PRODUCTS**

**CLASS 1211 02** - COMFORT CONDITIONING EQUIPMENT - Air Conditioning  
Apparatus

Air conditioning apparatus, Series SK 3328 , models SK3328.110, .114, .210, .510, .514 and SK 3328.610 rated 115 Vac,60Hz,single phase; models SK 3328.100, .104, .200, .500, .504 and SK 3328.600 rated 230 V, 60Hz, single phase, and models SK 3328.140, .144, .240, .540, .544 and SK 3328.640 rated 460Vac,60Hz, three phase, All with refrigerant R-134a, design pressure 406 psig.

## **Notes:**

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment