



# Certificate of Compliance

**Certificate:** 1673194

**Master Contract:** 153184

**Project:** 70000070

**Date Issued:** August 6, 2013

**Issued to:** **Rittal GmbH & Co. KG**  
**Auf dem Stuetzelberg 18**  
**Herborn, 35745**  
**Germany**  
**Attention: Rüdiger Gilardi**

*The products listed below are eligible to bear the CSA Mark shown*



*Nitin Bhople*

**Issued by:** Nitin Bhople

## **PRODUCTS**

**CLASS 1211 02** - COMFORT CONDITIONING EQUIPMENT - Air Conditioning  
Apparatus

Air conditioning apparatus, Series SK 3329 , models SK3329.110, .114, .210, .510, .514 and SK 3329.610 rated 115 Vac,60Hz,single phase; models SK3329.100, .104, .200, .500, .504 and SK 3329.600 rated 230 V ac,60Hz, single phase, and models SK3329.030, .140, .144, .240, .540, .544, and SK 3329.640 rated 460Vac, 60Hz, three phase. All with refrigerant R-134a. Design pressure 406 psig

## Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment