



# Certificate of Compliance

**Certificate:** 1745342

**Master Contract:** 153184

**Project:** 70000083

**Date Issued:** July 4, 2013

**Issued to:** **Rittal GmbH & Co. KG**  
**Auf dem Stuetzelberg 18**  
**Herborn, 35745**  
**Germany**  
**Attention: Rüdiger Gilardi**

*The products listed below are eligible to bear the CSA Mark shown*



*Nitin Bhople*

**Issued by:** Nitin Bhople

## **PRODUCTS**

**CLASS 1211 02** - COMFORT CONDITIONING EQUIPMENT - Air Conditioning Apparatus

Air conditioning apparatus, for use with enclosures, Series SK 3361 , models SK3361.110, .210, .510 and SK 3361.610 rated 115 Vac, 60Hz, single phase; models SK3361.100, .200, .500 and SK 3361.600 rated 230 V, 60Hz, single phase; models SK3361.140, .240, .540, and SK 3361.640 rated 400Vac, 60Hz, Three phase ( 2 conductors ). All with Refrigerant R-134a, design pressure 406 psig.

## Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment