

**Rittal – The System.**

Faster – better – everywhere.

# CERTIFICATE

## Rittal quality management

We hereby confirm that the design of the

Rittal plastic enclosures AX without viewing window

comply with the requirements according to IEC 60695-2-10:2014 GWT  
(glow wire test) 960°C and fulfill the protection V-0 according to UL94  
"Tests for Flammability of Plastic Material for Parts in Devices"



Axel Remmert  
Quality Management Laboratory

2022-02-07

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES



FRIEDHELM LOH GROUP